

2022年确山县污水处理厂月统计报表

填报单位：（盖章）

填报时间：2022年

月份	进水量 (万m3)	出水量 (万m3)	进水COD (mg/l)	出水COD (mg/l)	进水NH3-N (mg/l)	出水NH3-N (mg/l)	出水TP	出水TN	污泥产生量 (t)	絮凝剂消	耗电量 (万Kwh)	减排量(t)	
										耗量(kg)		COD	氨氮
1	96.07	94.92	263.0	17.19	42.28	1.231	0.169	11.097	622.6	560.4	32.04	236.31	39.65
2	86.86	85.78	303.0	15.57	44.92	0.782	0.101	12.547	554.4	499.0	28.97	248.50	38.57
3	97.56	96.51	266.0	17.57	34.17	0.415	0.068	11.096	617.5	555.7	33.69	241.33	32.83
4	93.91	92.89	285.2	14.10	38.42	0.426	0.052	10.880	599.7	539.7	33.09	254.83	35.66
5	103.52	102.37	303.4	13.79	41.16	0.300	0.118	10.959	617.89	556.1	37.94	299.72	42.21
6	102.41	101.25	201.0	11.26	27.15	0.086	0.143	10.632	593.3	534.0	31.80	194.15	27.68
7	107.00	105.92	235.0	10.61	25.46	0.072	0.103	10.169	613.6	552.3	41.87	240.32	27.21
8	109.80	108.63	255.0	12.58	33.12	0.186	0.074	10.133	615.8	554.2	31.99	266.04	36.13
9	108.15	107.11	278.0	12.24	35.99	0.289	0.130	8.463	598.0	538.2	35.03	287.10	38.59
10	112.65	111.50	248.0	12.77	27.11	0.473	0.135	8.570	615.9	554.3	34.89	264.76	30.00
11	100.6	99.75	250.0	11.73	30.47	0.110	0.129	8.338	565.5	508.9	37.32	247.93	31.61
12	99.63	98.69	257.0	11.50	29.48	0.183	0.071	8.906	614.5	553.0	37.22	244.64	29.17
合计	1218.16	1205.32	277.3	13.41	34.14	0.379	0.108	10.149	7228.7	6505.8	415.85	3025.63	409.31

注：表中污染物浓度、去除率在合计栏中填写月度均值